HAZARDOUS AREA (EX) EQUIPMENT · APPLETON

APPLETON SPEC 5 CONDUIT BODIES, COVERS AND GASKETS

CODE SPEC 5 | **SPEC 5**

Standards: UL 514A, 514B, UL Listed E2527, CSA



APPLETON SPEC 5

RANGE	Appleton Spec 5 · Hazardous area (Ex) equipment · 176 catalogue references
HAZARDOUS LOCATIONS	Class I, Div 2 (NEC 501.10(B)(4))
CONDUIT	Rigid conduit and IMC
BODY MATERIAL	Malleable iron
STANDARDS	UL 514A, 514B, UL Listed E2527, CSA C22.2 No. 18.3, NEMA FB-1
REFERENCES	• C-50 · type C, 1/2", malleable iron, Class I Div 2 • C-50G · type C, 1/2", malleable iron, hot dip galvanized, Class I Div 2 • C-75 · type C, 3/4", malleable iron, Class I Div 2 • C-75G · type C, 3/4", malleable iron, hot dip galvanized, Class I Div 2 • C-100 · type C, 1", malleable iron, Class I Div 2 • C-100G · type C, 1", malleable iron, hot dip galvanized, Class I Div 2 • C-125 · type C, 1-1/4", malleable iron, Class I Div 2 • C-125G · type C, 1-1/4", malleable iron, hot dip galvanized, Class I Div 2 • C-150 · type C, 1-1/2", malleable iron, Class I Div 2 • + 167 more references on sixwinds.com.sa (search "Appleton Spec")